

# Attestation

## Italian CAM

On the 14<sup>th</sup> of May 2024, Eurofins Product Testing A/S received a sample of wall covering with the product name:

### **Felt Family**

supplied by

### **Italreflexes Srl**

The emissions were tested according to the Italian CAM Decree DM 23 Giugno 2022 n. 254, GURI n. 183 del 6 agosto 2022 section 2.5.1. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2024-00230401\_A\_EN).

#### **Evaluation of the emission test result according to Italian CAM:**

---

- The relevant CMR compounds were not detectable after 28 days.
  - The sum of VOC ("TVOC") after 28 days was below the limit of 1500 µg/m<sup>3</sup>.
  - Formaldehyde after 28 days was below the limit of 60 µg/m<sup>3</sup>.
  - All other parameters were below their respective limit values after 28 days.
- 

22 July 2024



Rasmus Verdier  
Analytical Service Manager